



Product Service

CERTIFICATE

No. Z2 076043 0091 Rev. 01

Model(s):

DMxxx-M156-72, (xxx=335-375, in steps of 5)
 DMxxxM2-72SW, (xxx=335-375, in steps of 5)
 DMxxxM2-72BW, (xxx=335-375, in steps of 5)
 DMxxx-M156-60, (xxx=280-310, in steps of 5)
 DMxxxM2-60SW, (xxx=280-310, in steps of 5)
 DMxxxM2-60BW, (xxx=280-310, in steps of 5)
 DMHxxxM6-144SW, (xxx=340-385, in steps of 5)
 DMxxxM2-72HSW, (xxx=340-385, in steps of 5)
 DMxxxM2-72HBW, (xxx=340-385, in steps of 5)
 DMHxxxM6-120SW, (xxx=280-320, in steps of 5)
 DMxxxM2-60HSW, (xxx=280-320, in steps of 5)
 DMxxxM2-60HBW, (xxx=280-320, in steps of 5)
 DMxxxM156-72P, (xxx=335-375, in steps of 5)
 DMxxxM156-60P, (xxx=280-310, in steps of 5)
 DMxxxM156-36P, (xxx=175-190, in steps of 5)
 DMxxx-M159-72, (xxx=385-395, in steps of 5)
 DMxxxG1-72SW, (xxx=385-395, in steps of 5)
 DMxxxG1-72BW, (xxx=385-395, in steps of 5)
 DMxxx-M159-60, (xxx=315-325, in steps of 5)
 DMxxxG1-60SW, (xxx=315-325, in steps of 5)
 DMxxxG1-60BW, (xxx=315-325, in steps of 5)
 DMHxxxM6A-144SW, (xxx=380-405, in steps of 5)
 DMHxxxM6A-144BW, (xxx=380-405, in steps of 5)
 DMxxxG1-72HSW, (xxx=380-405, in steps of 5)
 DMxxxG1-72HBW, (xxx=380-405, in steps of 5)
 DMHxxxM6A-120SW, (xxx=320-335, in steps of 5)
 DMHxxxM6A-120BW, (xxx=320-335, in steps of 5)
 DMxxxG1-60HSW, (xxx=320-335, in steps of 5)
 DMxxxG1-60HBW, (xxx=320-335, in steps of 5)
 xxx is standing for the rated output power at STC

Parameters:

Safety Class:	Class II
Max. System Voltage:	1500V DC
Construction:	Framed, with Junction box, cable and connector.
Fire Safety Class:	Class C according to UL790.

Tested according to:

IEC 61215-1:2016
 IEC 61215-1-1:2016
 IEC 61215-2:2016
 IEC 61730-1:2016
 IEC 61730-2:2016
 IEC 62716:2013

Production Facility(ies):

076053

TÜV SÜD
 ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT