ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT

Product Service

CERTIFICATE

No. Z2 076043 0097 Rev. 01

Holder of Certificate: **Hengdian Group DMEGC Magnetics CO., LTD**
Hengdian Industrial Zone,
322118 Dongyang, Zhejiang
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 704062006202-01

Valid until: 2025-04-27

Date, 2020-04-30 (Zhulin Zhang)

A4 / 07.17

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT
TÜV SÜD

Product Service

CERTIFICATE

No. Z2 076043 0097 Rev. 01

Model(s):

DMxxx-M156-72, (xxx=335-375, in steps of 5)
DMxxx-M156-72BK, (xxx=335-375, in steps of 5)
DMxxx-M156-60, (xxx=280-310, in steps of 5)
DMxxx-M156-60BK, (xxx=280-310, in steps of 5)
DMHxxxM6-144SW, (xxx=340-385, in steps of 5)
DMHxxxM6-144BB, (xxx=340-385, in steps of 5)
DMHxxxM6-144BW, (xxx=340-385, in steps of 5)
DMHxxxM6-120SW, (xxx=280-320, in steps of 5)
DMHxxxM6-120BB, (xxx=280-320, in steps of 5)
DMHxxxM6-120BW, (xxx=280-320, in steps of 5)
DMxxx-M156-72P, (xxx=335-375, in steps of 5)
DMxxx-M156-60P, (xxx=280-310, in steps of 5)
DMxxx-M156-36P, (xxx=175-190, in steps of 5)
DMxxx-M159-72, (xxx=385-395, in steps of 5)
DMxxx-M159-72BK, (xxx=385-395, in steps of 5)
DMxxx-M159-60, (xxx=315-325, in steps of 5)
DMxxx-M159-60BK, (xxx=315-325, in steps of 5)
DMHxxxM6A-144SW, (xxx=380-405, in steps of 5)
DMHxxxM6A-144BB, (xxx=380-405, in steps of 5)
DMHxxxM6A-144BW, (xxx=380-405, in steps of 5)
DMHxxxM6A-120SW, (xxx=320-335, in steps of 5)
DMHxxxM6A-120BB, (xxx=320-335, in steps of 5)
DMHxxxM6A-120BW, (xxx=320-335, in steps of 5)
DMxxx-M159-72UB, (xxx=385-395, in steps of 5)
DMxxx-M159-60UB, (xxx=315-325, in steps of 5)
DMxxxG1-60SW, (xxx=315-325, in steps of 5)
DMxxxG1-60BW, (xxx=315-325, in steps of 5)
DMxxxG1-60HSW, (xxx=320-335, in steps of 5)
DMxxxG1-60HBW, (xxx=320-335, in steps of 5)
DMxxxG1-60BB, (xxx=315-325, in steps of 5)
DMxxxG1-60BU, (xxx=315-325, in steps of 5)
DMxxxG1-60HBB, (xxx=320-335, in steps of 5)
DMxxxG1-72SW, (xxx=385-395, in steps of 5)
DMxxxG1-72BW, (xxx=385-395, in steps of 5)
DMxxxG1-72HSW, (xxx=380-405, in steps of 5)
DMxxxG1-72HBW, (xxx=380-405, in steps of 5)
DMxxxG1-72BB, (xxx=385-395, in steps of 5)
DMxxxG1-72BU, (xxx=385-395, in steps of 5)
DMxxxG1-72HBB, (xxx=380-405, in steps of 5)
DMxxxM2-60SW, (xxx=280-310, in steps of 5)
DMxxxM2-60BW, (xxx=280-310, in steps of 5)
DMxxxM2-60HSW, (xxx=280-320, in steps of 5)
DMxxxM2-60HBW, (xxx=280-320, in steps of 5)
DMxxxM2-60BB, (xxx=280-310, in steps of 5)
DMxxxM2-60BU, (xxx=280-310, in steps of 5)
DMxxxM2-60HBB, (xxx=280-320, in steps of 5)
DMxxxM2-72SW, (xxx=335-375, in steps of 5)
DMxxxM2-72BW, (xxx=335-375, in steps of 5)
DMxxxM2-72HSW, (xxx=340-385, in steps of 5)
DMxxxM2-72HBW, (xxx=340-385, in steps of 5)
DMxxxM2-72BB, (xxx=335-375, in steps of 5)
DMxxxM2-72BU, (xxx=335-375, in steps of 5)
DMxxxM2-72HBB, (xxx=340-385, in steps of 5)
xxx is standing for rated output power at STC

TÜV®

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

TÜV SÜD ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT

Product Service

CERTIFICATE

No. Z2 076043 0097 Rev. 01

Parameters:

Severity of Salt mist test:	Severity 6
Safety Class:	Class II
Max. System Voltage:	1000V DC
Construction:	Framed, with Junction box, cable and connector.
Fire Safety Class:	Class C according to UL790.

Tested according to:

IEC 61215-1:2016
IEC 61215-1-1:2016
IEC 61215-2:2016
IEC 61730-1:2016
IEC 61730-2:2016
IEC 61701:2011

Production Facility(ies):

076053

A4 / 07.17

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®