



Product Service

CERTIFICATE

No. Z2 16 06 76043 058

Holder of Certificate: Hengdian Group DMEGC Magnetics CO., LTD
 Hengdian Industrial Zone,
 322118 Dongyang, Zhejiang
 PEOPLE'S REPUBLIC OF CHINA



Certification Mark:



Product: Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
 Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 704061088401-14

Valid until: 2021-06-12



Date, 2016-06-14

(Zhulin Zhang)

Page 1 of 7

**CERTIFICATE**

No. Z2 16 06 76043 058

Model(s):

DMxxx-M156-72, (xxx=255 to 360 in step of 5)
 DMxxx-M156-72BK, (xxx=255 to 360 in step of 5)
 DMxxx-M156-60, (xxx=220 to 300 in step of 5)
 DMxxx-M156-60BK, (xxx=220 to 300 in step of 5)
 DMxxx-M156-60L, (xxx=220 to 300 in step of 5)
 DMxxx-M156-60BL, (xxx=220 to 300 in step of 5)
 DMxxx-M125-96, (xxx=220 to 290 in step of 5)
 DMxxx-M125-96BK, (xxx=220 to 290 in step of 5)
 DMxxx-M125-72, (xxx=170 to 220 in step of 5)
 DMxxx-M125-72BK, (xxx=170 to 220 in step of 5)
 xxx is standing for rated output power at STC.
 others see attachment.

Parameters:

Rated Output Power at STC:	See attachment
Fire Safety Class:	Class C
Application Class:	Class A
Max. System Voltage:	1000V DC
Test Laboratory:	Yangzhou Opto-electrical products testing institute. No.10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P.R.China.
Construction:	Framed, with Junction box, cable and connector.

Tested according to:

IEC 61215(ed.2)
 EN 61215:2005
 IEC 61730-2(ed.1);am1
 EN 61730-2:2007/A1:2012
 IEC 61730-1(ed.1);am1;am2
 EN 61730-1:2007/A2:2013

Production Facility(ies):

76053